



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 7/17/09

Code 50.10.7-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title R606.2 Thickness of masonry		Page 1 of 1
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
R606.2 Thickness of masonry. The nominal thickness of <u>above-grade</u> masonry walls shall conform...		
REASON AND FISCAL IMPACT		
This proposal gives clear direction that this section of the code is for use on above-grade masonry walls and not foundation walls.		
Fiscal impact: there is no increase to he cost of construction.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		